

FUEL STORAGE TANK PERMIT, CONSTRUCTION DOCUMENT, AND INSPECTION INFORMATION

Product In The Tank	Where The Tank Is Being Placed	Activity	Fire Prevention Code			Virginia Uniform Statewide Building Code		
			Permit	Construction Documents	Insp.	Permit	Construction Documents	Insp.
Liquefied Petroleum Gas LPG (NFPA 58)	Commercial	Installation	Yes single tanks greater than 30 gallons, and multiple tanks greater than 60 gallons	Yes	Yes	Yes	Yes	Yes
	Commercial	Abandonment/removal/closure	No	No	No	No	No	No
	Residential	Installation	No	No	No	Yes	No	Yes
	Residential	Abandonment/removal/closure	No	No	No	No	No	No
Diesel Fuel or Gasoline	Commercial ^{4,5}	Installation	Yes if greater than 60 gallons	Yes	Yes	Yes	Yes	Yes
	Commercial ^{1,4,5}	Abandonment/removal/closure	No	No	Yes	Yes	No	Yes
	Residential ^{2,5}	Installation	No	No	No	Yes	No	Yes
	Residential ^{1,2,5}	Abandonment/removal/closure	No	No	No	Yes	No	Yes
Fuel Oil	Commercial ^{5,6}	Installation	Yes if greater than 60 gallons	Yes	Yes	Yes	Yes	Yes
	Commercial ^{1,4,5}	Abandonment/removal/closure	Yes	No	Yes	Yes	No	Yes
	Residential ⁵	Installation	No	No	No	Yes	No	Yes
	Residential ^{1,3,5}	Abandonment/removal/closure	No	No	No	Yes	No	Yes

- 1 Owner is required to submit the results of soil sample(s) to the Dept. of Environmental Quality (DEQ) for evaluation after the abandonment /removal /closure of the registered tank(s). Owner must report sample results greater than 100ppm TPH within 24 hours of release discovery to the Regional DEQ Office (DEQ Telephone # 800-592-5482).
- 2 Above ground/ below ground storage tanks greater than 1100 gallons: Department of Environmental Quality regulations shall also apply.
- 3 Above ground tanks greater than 660: Department of Environmental Quality regulations shall also apply.
- 4 Above ground storage tanks greater than 660 gallons and below ground storage tanks greater than 110 gallons: Department of Environmental Quality regulations shall also apply.
- 5 Above ground tanks greater than 660 gallons shall be registered in accordance with the State Water Control Board regulations.
- 6 Department of Environmental Quality regulations shall not apply to underground storage tanks where the stored fuel oil is consumed on the premises where stored.